



GENERAL NOTES AND SPECIFICATIONS

1. ALL CONSTRUCTION SHALL COMPLY WITH THE MADERA COUNTY CODE
2. GROUT ALL CELLS
3. ALL MASONRY UNITS SHALL COMPLY WITH THE LATEST ADOPTED CBC, CALIFORNIA BUILDING CODE.
4. DEPTH OF FOOTINGS ARE INTO NATURAL UNDISTURBED SOIL OR TESTED AND APPROVED COMPACTED FILL.
5. ALL MASONRY SHALL BE MINIMUM, $f'_m=1500$ PSI.
6. REINFORCING BARS SHALL BE DEFORMED BARS MINIMUM GRADE 40.
7. FOOTING CONCRETE SHALL BE A MINIMUM 2500 PSI AT 28 DAYS.
8. THIS DESIGN SHALL NOT BE USED FOR RETAINING EARTH
9. MORTAR SHALL BE TYPE-S (MINIMUM 2000 PSI AT 28 DAYS)
 - ONE (1) PART CEMENT, TYPE 1
 - ONE-HALF (1/2) PART LIME PUTTY OR HYDRATED LIME
 - FOUR AND ONE-HALF (4 1/2) PARTS SAND (MAXIMUM)
10. GROUT SHALL BE A MINIMUM 2000 PSI AT 28 DAYS
 - ONE(1) PART CEMENT
 - THREE(3) PARTS SAND
 - TWO(2) PARTS PEA GRAVEL
11. STAND BOND UPON SUBMITTAL ONLY
12. ALL LAPS MUST BE TIED WITH TIE WIRE
13. ALL MASONRY WALLS SHALL BE INSPECTED BY AN AGENCY APPROVED BY THE THE COUNTY OF MADERA.

V:\CAD Files\B Dwg\B-2 6-Inch Masonry Wall.DWG 10-17-11 02:07:27 PM eli.mcfarland

| | | |
|----------------------------|--------------------------------------|--------------------|
| Spec's By _____ | COUNTY OF MADERA | Date: 07-31-09 |
| Drawn By <u>J. SHIELDS</u> | | Scale: NONE |
| APPROVED BY _____ | SIX (6) INCH MASONRY WALL | Drawing No. B-2 |
| REVISIONS 7/20/2011 | | |