



KEY SWITCH TO BE MOUNTED ON EXTERIOR, EITHER ON STEEL GOOSENECK OR ON WALL OR GATE POST WITHIN 3' OF ROADWAY AND NOT OVER 15' FROM GATE.

GATE CLEARANCE IS TO BE NO LESS THAN 14'-0"

BY-PASS SWITCH REQUIREMENTS

1. The by-pass cylinder or pad lock will be Knox Box System Electric Switch Cylinder.
2. A sign shall be placed adjacent to each cylinder. It will be a minimum 3" high with letters at least 2" high. The word "FIRE" will be white on a red background.
3. During construction of a new development, contact Madera County Fire Department for details.
4. The cylinder or Knox pad lock is to be purchased by the owner or contractor.
5. Standard security gate – Vertical clearance not less than 15'-0". Width not less than 14'-0".

V:\CAD Files\B Dwg\B-7 Emergency Access.DWG 10-17-11 02:07:56 PM eli.mcfarland

Spec's By _____	COUNTY OF MADERA EMERGENCY ACCESS, SECURED COMPLEX BY-PASS	Date: 4-16-91
Drawn By <u>J. SHIELDS</u>		Scale: NONE
APPROVED BY _____		Drawing No. B-7
REVISIONS	8/1/02	10/1/02