


NOTES:

1. ELEVATION 'B' SHALL BE ESTABLISHED BY USING THE LONGER SWALE DISTANCE WITH A GRADE OF 1% MINIMUM. ON LONG LOTS 0.5% GRADIENT TO REAR MAY BE ALLOWED IF APPROVED BY BUILDING OFFICIAL.
2. BUILDING PADS SHALL BE 0.5' (6") ABOVE THE HIGHEST POINT IN THE SWALE (ELEVATION 'B') OR AS APPROVED BY THE BUILDING OFFICIAL.
3. FINISHED PAD SHALL BE SUFFICIENTLY ELEVATED TO PLACE LOWEST FLOOR AT OR ABOVE BASE FLOOD LEVEL. EXCEPTIONS TO BE REVIEWED AND APPROVED BY JURISDICTION.
4. DURING CONSTRUCTION STORM DRAIN CONTROL SHALL BE IMPLEMENTED TO PREVENT FLOODING ADJACENT PROPERTY, AND TO PREVENT EROSION AND RETAIN SOIL RUNOFF ON THE SITE. RETENTION BASIN, FILTERED BARRIERS, WATTLE OR OTHER APPROVED METHOD AS REQUIRED.
5. 5% MINIMUM SLOPE 10' MINIMUM AWAY FROM STRUCTURE UNLESS OTHERWISE APPROVED BY JURISDICTION.

* EXCEPTIONS TO BE REVIEWED AND APPROVED BY JURISDICTION.



V:\CAD Files\E Dwg\E-5A Site Drainage.dwg 10-17-11 11:00:11 AM eli.mcfarland

Spec's By _____	COUNTY OF MADERA	Date: 8-21-98
Drawn By <u>J. SHIELDS</u>		Scale: NONE
APPROVED BY _____		Drawing No. E-5A
REVISIONS	8/1/02	8/12/11