



*METER BOX SET 1" ABOVE EXISTING GRADE

OR AS DIRECTED BY COUNTY ENGINEERING

1.5'

2'

12" MAX.

ANGLE METER STOP

PLACE WATER CAP IF WILL NOT CONNECT FOR SERVICE

*10 3/4" SPOOL FOR 1" METER

13" SPOOL FOR 1 1/2" METER

17" SPOOL FOR 2" METER

*METER BOX SPECIFICATIONS
1 1/4", 1 1/2", 2" SERVICE CHRISTY B-16
3/4", 1" SERVICE CHRISTY B-9

- NOTES:**
1. WATER MAIN SERVICE SADDLES SHALL BE OF BRONZE CONSTRUCTION. DOUBLE STRAPS REQUIRED.
 2. USE "NEPTUNE" TRIDENT 8 WATER METER WITHOUT MAGNETIC HEAD. METER SHALL HAVE STANDARD REGISTER FOR DIRECT READING IN U.S. GALLONS WITH FLANGED ENDS.
 3. METERS FOR 1 1/2" SERVICES OR LARGER TO BE INSTALLED AT THE DISCRETION OF THE COUNTY ENGINEER.

Spec's By _____	COUNTY OF MADERA	Date: 1-4-99			
Drawn By J. SHIELDS		Scale: NONE			
APPROVED BY _____		Drawing No. W-7F			
REVISIONS	8/1/02	8/21/09	4/22/2011		